

2018.gada 4.jūlijā  
Uz

Nr. 500300/2.5/2018/2586  
Nr.

Sarunu procedūras kandidātiem/  
Tenderers of the negotiated procedure

Par sarunu procedūru Nr.AST2018/43 "Latvijas elektrostaciju dinamisko modeļu validācija" - atbildes uz pretendenta jautājumiem /

Subject: Negotiation procedure No AST2018/43 "The validation of the dynamic models of Latvian power plants" - answers to the tenderer questions

Ļ.cien. dāmas/ A.god. kungi!

Ar šo atbildam uz pretendenta iesniegtajiem jautājumiem.

**1. Jautājums:** *Kādā apjomā pakalpojumu sniedzējam ir jāuzņemas darbu organizēšana un veikšana pagaidu mērierīču uzstādīšanā minētajos objektos? Vai pakalpojumu sniedzējs var piedalīties kā konsultants vai arī ir darbu organizētājs un veicējs objektos?*

**Atbilde:** Plānots, ka Pakalpojuma sniedzējs sagatavos sarakstu, kurā ir norādīts, kādi lielumi ir jāreģistrē testu laikā, tam nepieciešamās mērierīces un to uzstādīšanas vietas. Ja kādus mērījumus nevar veikt ar esošajām mērierīcēm, Pakalpojuma sniedzējs piegādās nepieciešamās pagaidu mērierīces. Pasūtītājs saskaņos ar ģenerējošo iekārtu īpašnieku mērierīču pieslēgšanu. Pakalpojuma sniedzējs pārraudzīs un konsultēs uzstādīšanas procesu.

**2. Jautājums:** *Kādā apjomā Pasūtītājs organizēs un nodrošinās Pakalpojumu sniedzējam piekļuvi iekārtām objektos un testu veikšanai nepieciešamās darbības un procedūras, lai veiktu minētos testus? Vai atbildīgā persona par testu veikšanu un izpildi ir Pakalpojumu sniedzējs?*

**Atbilde:** Pasūtītājs saskaņos ar ģenerators īpašnieku nepieciešamo testu veikšanas kārtību un programmu. Pasūtītājs saskaņos ar ģenerējošo iekārtu īpašnieku Pakalpojuma sniedzēja piekļuvi objektiem. Testus veiks ģenerējošo iekārtu īpašnieka personāls atbilstoši testa programmai Pasūtītāja un Pakalpojuma sniedzēja uzraudzībā.

*Translation in the English:*

Dear Sir/Madam!

Hereby the Customer answers to the tenderer questions.

**Question 1:** *What amount of work administration and execution shall the Service provider undertake when installing temporary measurement devices? Shall the Service provider participate as a consultant or work organizer and maker?*

**Answer:** It is planned that Service provider will prepare the list of measurements to be captured during the test, list of measurement devices needed and connection points for those measurement devices. If some measurements cannot be captured with existing devices, Service provider delivers additional (temporary) measurement devices. Customer will coordinate connection of temporary measurement devices with generating company owner. Service provider will consult and supervise installation of measurement devices.

**Question 2:** *What will be involvement of Customer to ensure Service provider access to generating facility and test procedures and actions needed to perform tests? Will the Service provider be responsible party for performing the tests?*

**Answer:** Customer will coordinate test procedures and program with generating company owner. Customer will communicate with generating company owner to ensure Service provider access to the generating facility. Tests will be performed by the generating company according to the test program and under supervision of Customer and Service provider.

Ar cieņu/ Yours faithfully

Valdes loceklis  
Member of the Management Board

Mārcis Kauliņš



Kapče 67725552